

“Summary A Draft Suggestion on the Dose Constraints for Korean NPPs based on ICRP-103 Recommendations”

Hee geun Kim, Korea Electric Power Research Institute (Korea)

As to dose constraints for design stage, the following discussions are presented.

- The example of collective dose for Korean NPPs design
 - Target of collective dose : 1.0 person·Sv/unit·yr
 - Expected dose at NPP design : 0.76 person·Sv/unit·yr
- KINS KNGR's Safety Requirement (Dose constraints)
 - Maximum individual dose : 5.0 mSv/yr, Average dose : 2.0 mSv/yr
- The example of dose constraints for Korean NPPs design
 - Maximum individual dose : 10 mSv/yr, Average dose : 2.0 mSv/yr
- Expected occupational dose
 - Maximum individual dose : 7.0 mSv/yr, Average dose : 0.84 mSv/yr
 - No meet for dose constraints. But the minimum workers involved and increase worker capability at operation/maintenance period

As to dose constraints for operation/maintenance (o/m) stage, the following discussions are presented.

- The dose limits : 100 mSv/5years (averaging 20 mSv/yr)
- Dose Constraint for O/M : > 80% of limit (16 mSv/yr)

As to dose constraints for the public, the following discussions are presented.

- Draft dose constraint for the member of public
 - Dose constraint for single reactor unit : 0.1 - 0.2 mSv/yr
 - Dose constraint for a site : 0.6 mSv/yr
 - Delete the dose constraint for a site, if necessary