

3. 放射性液体廃棄物中の放射性物質（<sup>3</sup>Hを除く）の年度別放出実績

年度 発電所名	1988	1989	1990	1991
日本原子力発電(株) 東海発電所	$3.1 \times 10^7$ ( $8.5 \times 10^{-4}$ )	$1.5 \times 10^7$	$3.4 \times 10^7$	$1.6 \times 10^7$
日本原子力発電(株) 東海第二発電所	N.D.	N.D.	N.D.	N.D.
日本原子力発電(株) 敦賀発電所	$1.1 \times 10^7$ ( $3.0 \times 10^{-4}$ )	$4.2 \times 10^6$	$5.6 \times 10^6$	$6.6 \times 10^6$
東北電力(株) 女川原子力発電所	N.D.	N.D.	N.D.	N.D.
東京電力(株) 福島第一原子力発電所	N.D.	N.D.	N.D.	N.D.
東京電力(株) 福島第二原子力発電所	N.D.	N.D.	N.D.	N.D.
東京電力(株) 柏崎刈羽原子力発電所	N.D.	$7.3 \times 10^5$	N.D.	N.D.
中部電力(株) 浜岡原子力発電所	$1.2 \times 10^7$ ( $3.3 \times 10^{-4}$ )	$1.1 \times 10^7$	$9.1 \times 10^6$	$5.2 \times 10^6$
北陸電力(株) 志賀原子力発電所				
中国電力(株) 島根原子力発電所	$5.9 \times 10^6$ ( $1.6 \times 10^{-4}$ )	$3.4 \times 10^6$	$6.2 \times 10^5$	$1.5 \times 10^6$
北海道電力(株) 泊発電所	N.D.	N.D.	N.D.	N.D.
関西電力(株) 美浜発電所	$2.1 \times 10^7$ ( $5.6 \times 10^{-4}$ )	$6.5 \times 10^6$	$1.6 \times 10^7$	$5.1 \times 10^5$
関西電力(株) 高浜発電所	N.D.	N.D.	N.D.	N.D.
関西電力(株) 大飯発電所	$2.1 \times 10^5$ ( $5.7 \times 10^{-6}$ )	N.D.	$7.4 \times 10^5$	N.D.
四国電力(株) 伊方発電所	N.D.	N.D.	N.D.	N.D.
九州電力(株) 玄海原子力発電所	N.D.	N.D.	N.D.	N.D.
九州電力(株) 川内原子力発電所	N.D.	N.D.	N.D.	N.D.

注) 1988年度以前の数値はキュリー単位で報告された値をベクレル単位に換算したものである。

注) (単位：ベクレル。ただし、( )内はキュリー)

1992	1993	1994	1995	1996	1997
$1.6 \times 10^7$	$6.7 \times 10^6$	$1.5 \times 10^6$	$8.9 \times 10^6$	$6.4 \times 10^6$	$2.9 \times 10^6$
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$2.5 \times 10^6$	$1.5 \times 10^5$	N.D.	$9.4 \times 10^4$	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$2.4 \times 10^6$	$6.0 \times 10^5$	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$2.4 \times 10^6$	$2.2 \times 10^6$	$4.6 \times 10^5$	$7.0 \times 10^4$	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$3.0 \times 10^6$	$3.4 \times 10^5$	$1.0 \times 10^5$	$4.8 \times 10^5$	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$7.8 \times 10^4$	$1.4 \times 10^5$	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.