

参考資料 1 . 気体廃棄物中の放射性希ガスの年度別放出量

(単位：ベクレル)

年度 発電所名	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998
日本原子力発電(株) 東海発電所	2.1×10^{14}	2.7×10^{14}	2.5×10^{14}	3.0×10^{14}	N.D.	2.8×10^{14}	2.5×10^{14}	3.1×10^{14}	3.6×10^{14}	N.D.
日本原子力発電(株) 東海第二発電所	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
日本原子力発電(株) 敦賀発電所	8.9×10^9	1.0×10^{10}	1.0×10^{10}	2.9×10^9	2.7×10^9	3.6×10^9	3.8×10^8	3.8×10^9	3.0×10^9	8.4×10^8
東北電力(株) 女川原子力発電所	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
東京電力(株) 福島第一原子力発電所	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
東京電力(株) 福島第二原子力発電所	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
東京電力(株) 柏崎刈羽原子力発電所	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
中部電力(株) 浜岡原子力発電所	N.D.	N.D.	N.D.	N.D.	N.D.	1.9×10^{11}	N.D.	N.D.	N.D.	N.D.
北陸電力(株) 志賀原子力発電所	-	-	-	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
中国電力(株) 島根原子力発電所	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
北海道電力(株) 泊発電所	1.7×10^8	7.3×10^8	3.8×10^9	1.6×10^9	1.7×10^8	4.1×10^8	2.5×10^9	3.0×10^9	2.4×10^9	1.3×10^9
関西電力(株) 美浜発電所	2.5×10^{11}	2.7×10^{11}	2.8×10^{11}	1.1×10^{12}	2.0×10^{11}	1.1×10^{11}	1.6×10^{11}	1.9×10^{11}	1.9×10^{11}	1.7×10^{11}
関西電力(株) 高浜発電所	3.5×10^{11}	3.5×10^{11}	1.8×10^{12}	4.4×10^{11}	6.2×10^{11}	2.0×10^{11}	2.1×10^{11}	3.3×10^{11}	3.7×10^{11}	4.2×10^{11}
関西電力(株) 大飯発電所	1.0×10^{12}	6.8×10^{11}	5.6×10^{11}	5.3×10^{11}	4.7×10^{11}	6.0×10^{11}	5.1×10^{11}	4.3×10^{11}	4.3×10^{11}	6.1×10^{11}
四国電力(株) 伊方発電所	5.9×10^9	4.2×10^9	2.8×10^{10}	4.8×10^{11}	7.2×10^9	5.7×10^8	1.1×10^9	4.5×10^9	6.0×10^8	1.1×10^8
九州電力(株) 玄海原子力発電所	6.9×10^{11}	6.5×10^{11}	5.2×10^{11}	3.7×10^{11}	2.3×10^{11}	1.7×10^{11}	1.3×10^{11}	8.5×10^{10}	6.6×10^{10}	3.1×10^{11}
九州電力(株) 川内原子力発電所	4.0×10^{10}	5.9×10^{10}	3.2×10^{10}	3.8×10^{10}	3.0×10^{10}	3.2×10^{10}	3.9×10^{10}	3.7×10^{10}	3.4×10^{10}	3.7×10^{10}
合計 (N.D. を除く)	2.12×10^{14}	2.72×10^{14}	2.53×10^{14}	3.03×10^{14}	1.56×10^{12}	2.81×10^{14}	2.51×10^{14}	3.11×10^{14}	3.61×10^{14}	1.56×10^{12}

