

## (15) Radiation Dosage of Shikoku Electric Power Co., Inc.'s Ikata Power Station

Item \ FY		1989	1990	1991	1992	1993	1994	1995	1996	1997	1998
Number of personnel engaged in radiation work (number of personnel)	Employee	276	270	301	275	436	444	401	414	466	413
	Others	1,731	1,741	1,477	1,759	2,428	2,202	1,990	2,099	2,729	2,152
	Total	2,007	2,011	1,778	2,034	2,864	2,646	2,391	2,513	3,195	2,565
Collective dose (person-Sv)	Employee	0.13	0.10	0.06	0.06	0.10	0.06	0.05	0.07	0.09	0.07
	Others	2.16	2.53	1.13	1.20	2.17	1.28	1.12	2.23	3.00	1.46
	Total	2.29	2.63	1.19	1.26	2.26	1.34	1.17	2.29	3.09	1.53
Average individual dosage (mSv)	Employee	0.5	0.4	0.2	0.2	0.2	0.1	0.1	0.2	0.2	0.2
	Others	1.2	1.5	0.8	0.7	0.9	0.6	0.6	1.1	1.1	0.7
	Total	1.1	1.3	0.7	0.6	0.8	0.5	0.5	0.9	1.0	0.6
Number of reactors		2	2	2	2	3	3	3	3	3	3

## (16) Radiation Dosage of Kyushu Electric Power Co., Inc.'s Genkai Nuclear Power Station

Item \ FY		1989	1990	1991	1992	1993	1994	1995	1996	1997	1998
Number of personnel engaged in radiation work (number of personnel)	Employee	266	250	251	359	415	448	479	495	499	458
	Others	1,551	1,607	1,497	2,187	2,573	3,109	2,423	2,934	3,116	3,152
	Total	1,817	1,857	1,748	2,546	2,988	3,557	2,902	3,429	3,615	3,610
Collective dose (person-Sv)	Employee	0.09	0.08	0.03	0.04	0.07	0.08	0.04	0.05	0.08	0.11
	Others	3.09	3.86	2.24	1.99	2.46	2.67	1.67	1.82	3.12	3.89
	Total	3.17	3.94	2.27	2.04	2.53	2.75	1.71	1.88	3.20	4.00
Average individual dosage (mSv)	Employee	0.3	0.3	0.1	0.1	0.2	0.2	0.1	0.1	0.2	0.3
	Others	2.0	2.4	1.5	0.9	1.0	0.9	0.7	0.6	1.0	1.2
	Total	1.7	2.1	1.3	0.8	0.9	0.8	0.6	0.6	0.9	1.1
Number of reactors		2	2	2	2	3	3	3	4	4	4