

## (15) Radiation Dosage of Shikoku Electric Power Co., Inc.'s Ikata Power Station

Item \ FY		1990	1991	1992	1993	1994	1995	1996	1997	1998	1999
Number of personnel engaged in radiation work (number of personnel)	Employee	270	301	275	436	444	401	414	466	413	399
	Others	1,741	1,477	1,759	2,428	2,202	1,990	2,099	2,729	2,152	2,092
	Total	2,011	1,778	2,034	2,864	2,646	2,391	2,513	3,195	2,565	2,491
Collective dose (person-Sv)	Employee	0.10	0.06	0.06	0.10	0.06	0.05	0.07	0.09	0.07	0.08
	Others	2.53	1.13	1.20	2.17	1.28	1.12	2.23	3.00	1.46	1.78
	Total	2.63	1.19	1.26	2.26	1.34	1.17	2.29	3.09	1.53	1.86
Average individual dosage (mSv)	Employee	0.4	0.2	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.2
	Others	1.5	0.8	0.7	0.9	0.6	0.6	1.1	1.1	0.7	0.9
	Total	1.3	0.7	0.6	0.8	0.5	0.5	0.9	1.0	0.6	0.7
Number of reactors		2	2	2	3	3	3	3	3	3	3

## (16) Radiation Dosage of Kyushu Electric Power Co., Inc.'s Genkai Nuclear Power Station

Item \ FY		1990	1991	1992	1993	1994	1995	1996	1997	1998	1999
Number of personnel engaged in radiation work (number of personnel)	Employee	250	251	359	415	448	479	495	499	458	458
	Others	1,607	1,497	2,187	2,573	3,109	2,423	2,934	3,116	3,152	2,876
	Total	1,857	1,748	2,546	2,988	3,557	2,902	3,429	3,615	3,610	3,334
Collective dose (person-Sv)	Employee	0.08	0.03	0.04	0.07	0.08	0.04	0.05	0.08	0.11	0.08
	Others	3.86	2.24	1.99	2.46	2.67	1.67	1.82	3.12	3.89	2.99
	Total	3.94	2.27	2.04	2.53	2.75	1.71	1.88	3.20	4.00	3.07
Average individual dosage (mSv)	Employee	0.3	0.1	0.1	0.2	0.2	0.1	0.1	0.2	0.3	0.2
	Others	2.4	1.5	0.9	1.0	0.9	0.7	0.6	1.0	1.2	1.0
	Total	2.1	1.3	0.8	0.9	0.8	0.6	0.6	0.9	1.1	0.9
Number of reactors		2	2	2	3	3	3	4	4	4	4