

(15) Radiation Dosage of Shikoku Electric Power Co., Inc.'s Ikata Power Station

Item \ FY		1992	1993	1994	1995	1996	1997	1998	1999	2000	2001
Number of personnel engaged in radiation work (number of personnel)	Employee	275	436	444	401	414	466	413	399	374	419
	Others	1,759	2,428	2,202	1,990	2,099	2,729	2,152	2,092	2,364	2,960
	Total	2,034	2,864	2,646	2,391	2,513	3,195	2,565	2,491	2,738	3,379
Collective dose (person-Sv)	Employee	0.06	0.10	0.06	0.05	0.07	0.09	0.07	0.08	0.12	0.16
	Others	1.20	2.17	1.28	1.12	2.23	3.00	1.46	1.78	3.51	5.01
	Total	1.26	2.26	1.34	1.17	2.29	3.09	1.53	1.86	3.62	5.16
Average individual dosage (mSv)	Employee	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.4
	Others	0.7	0.9	0.6	0.6	1.1	1.1	0.7	0.9	1.5	1.7
	Total	0.6	0.8	0.5	0.5	0.9	1.0	0.6	0.7	1.3	1.5
Number of reactors		2	3	3	3	3	3	3	3	3	3

(16) Radiation Dosage of Kyushu Electric Power Co., Inc.'s Genkai Power Station

Item \ FY		1992	1993	1994	1995	1996	1997	1998	1999	2000	2001
Number of personnel engaged in radiation work (number of personnel)	Employee	359	415	448	479	495	499	458	458	468	459
	Others	2,187	2,573	3,109	2,423	2,934	3,116	3,152	2,876	3,103	4,137
	Total	2,546	2,988	3,557	2,902	3,429	3,615	3,610	3,334	3,571	4,596
Collective dose (person-Sv)	Employee	0.04	0.07	0.08	0.04	0.05	0.08	0.11	0.08	0.06	0.11
	Others	1.99	2.46	2.67	1.67	1.82	3.12	3.89	2.99	1.96	4.98
	Total	2.04	2.53	2.75	1.71	1.88	3.20	4.00	3.07	2.02	5.09
Average individual dosage (mSv)	Employee	0.1	0.2	0.2	0.1	0.1	0.2	0.3	0.2	0.1	0.2
	Others	0.9	1.0	0.9	0.7	0.6	1.0	1.2	1.0	0.6	1.2
	Total	0.8	0.9	0.8	0.6	0.6	0.9	1.1	0.9	0.6	1.1
Number of reactors		2	3	3	3	4	4	4	4	4	4