

## Status of Gaseous and Liquid Waste Management

### ① Commercial Power Reactor Facilities

Power plant		Radioactive gaseous waste		Radioactivity Radioactive liquid waste (excluding $^3\text{H}$ ) (Bq)
		Noble gas (Bq)	Iodine (Bq)	
*1 Japan Atomic Power Company Co., Ltd Tokai Power Station	Nuclear reactor facilities total	-	-	4 $8.9 \times 10$
	Annual release			7
	Target control level	-	-	$7.4 \times 10$
Japan Atomic Power Company Co., Ltd. Tokai Daini Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	10	10
	Target control level	$1.4 \times 10$	$5.9 \times 10$	$3.7 \times 10$
Japan Atomic Power Company Co., Ltd. Tsuruga Power Station	Nuclear reactor facilities total	9 $1.6 \times 10$	N.D.	N.D.
	Annual release	15	10	10
	Target control level	$1.7 \times 10$	$3.8 \times 10$	$7.4 \times 10$
Tohoku Electric Power Co., Inc. Onagawa Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	11	10
	Target control level	$3.8 \times 10$	$1.3 \times 10$	$1.1 \times 10$
Tokyo Electric Power Co., Inc. Fukushima Daiichi Nuclear Power Station	Nuclear reactor facilities total	7 $2.8 \times 10$	N.D.	N.D.
	Annual release	15	11	11
	Target control level	$8.8 \times 10$	$4.8 \times 10$	$2.2 \times 10$
Tokyo Electric Power Co., Inc. Fukushima Daini Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	11	11
	Target control level	$5.5 \times 10$	$2.3 \times 10$	$1.4 \times 10$
Tokyo Electric Power Co., Inc. Kashiwazaki-Kariwa Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	11	11
	Target control level	$6.7 \times 10$	$2.3 \times 10$	$2.5 \times 10$
Chubu Electric Power Co., Inc. Hamaoka Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	11	11
	Target control level	$6.3 \times 10$	$3.1 \times 10$	$1.8 \times 10$
Hokuriku Electric Power Co. Shika Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	10	10
	Target control level	$1.1 \times 10$	$3.0 \times 10$	$3.7 \times 10$
Chugoku Electric Power Co., Inc. Shimane Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release	15	11	10
	Target control level	$2.5 \times 10$	$1.3 \times 10$	$7.4 \times 10$

\*1: Due to the commencement of the decommissioning process on December 4, 2001,  $^{60}\text{Co}$ ,  $^{134}\text{Cs}$  and  $^{137}\text{Cs}$  are the subjects of the annual release control targets for radioactive liquid waste.

Power plant		Radioactive gaseous waste		Radioactivity Radioactive liquid waste (excluding <sup>3</sup> H) (Bq)
		Noble gas (Bq)	Iodine (Bq)	
Hokkaido Electric Power Co., Inc. Tomari Power Station	Nuclear reactor facilities total	<sup>9</sup> 5.1×10	N.D.	N.D.
	Annual release Target control level	<sup>15</sup> 1.1×10	<sup>10</sup> 1.1×10	<sup>10</sup> 7.4×10
Kansai Electric Power Co., Inc. Mihama Power Station	Nuclear reactor facilities total	<sup>9</sup> 6.1×10	<sup>5</sup> 2.3×10	N.D.
	Annual release Target control level	<sup>15</sup> 2.1×10	<sup>10</sup> 7.4×10	<sup>11</sup> 1.1×10
Kansai Electric Power Co., Inc. Takahama Power Station	Nuclear reactor facilities total	<sup>10</sup> 1.1×10	N.D.	N.D.
	Annual release Target control level	<sup>15</sup> 3.3×10	<sup>10</sup> 6.2×10	<sup>11</sup> 1.4×10
Kansai Electric Power Co., Inc. Ohi Power Station	Nuclear reactor facilities total	<sup>10</sup> 1.8×10	N.D.	N.D.
	Annual release Target control level	<sup>15</sup> 3.7×10	<sup>11</sup> 1.0×10	<sup>11</sup> 1.4×10
Kyushu Electric Power Co., Inc. Genkai Nuclear Power Plant	Nuclear reactor facilities total	<sup>9</sup> 7.5×10	N.D.	N.D.
	Annual release Target control level	<sup>15</sup> 1.5×10	<sup>10</sup> 8.1×10	<sup>11</sup> 1.1×10
Shikoku Electric Power Co., Inc. Ikata Nuclear Power Plant	Nuclear reactor facilities total	<sup>9</sup> 9.9×10	N.D.	N.D.
	Annual release Target control level	<sup>15</sup> 2.2×10	<sup>10</sup> 5.9×10	<sup>11</sup> 1.4×10
Kyushu Electric Power Co., Inc. Sendai Nuclear Power Station	Nuclear reactor facilities total	<sup>10</sup> 3.1×10	N.D.	N.D.
	Annual release Target control level	<sup>15</sup> 1.6×10	<sup>10</sup> 6.2×10	<sup>10</sup> 7.4×10

Notes: The radioactivity (Bq) of gaseous (or liquid) waste is obtained by multiplying the concentration of the radioactive material (Bq/cm<sup>3</sup>) in the released gas (or liquid) by the amount of released gas (or liquid) (m<sup>3</sup>). Values lower than the detection limit of radioactivity are indicated as N.D.

The detection limits are as follows.

Radioactive noble gases:  $2 \times 10^{-2}$  (Bq/cm<sup>3</sup>) or less

Radioactive iodine:  $7 \times 10^{-9}$  (Bq/cm<sup>3</sup>) or less

Radioactive liquid waste (excluding <sup>3</sup>H):  $2 \times 10^{-2}$  (Bq/cm<sup>3</sup>) or less ( the <sup>60</sup>Co value is used)