

XVII-1 Status of Radioactive Waste Management

(1) Release of Gaseous and Liquid Radioactive Waste

1) Commercial Nuclear Power Reactor Facilities

The release of gaseous and liquid radioactive waste is controlled at every nuclear power plant not to exceed the prescribed dose limit for the public in the area (i.e., 50 $\mu\text{Sv}/\text{year}$) in accordance with the "Guide for Dose Objectives around Light Water Nuclear Power Reactor Facilities". The annual emission control target levels are determined in the safety provisions based on the values evaluated at the time of the safety assessment which takes place prior to the establishment of the facilities, and the emission is controlled not to exceed target levels.

In FY2003, the emission was lower than the target emission level at every nuclear power plant.

The results of the evaluation, which was performed in accordance with the "Evaluation Guide for Dose Objectives around Light Water Nuclear Power Reactor Facilities" show that the equivalent dose of public exposure was less than 1 μSv per year.

2) Nuclear Power Reactor Facilities in a Research and Development Stage

The release of gaseous and liquid radioactive waste is controlled not to exceed the annual emission control levels, which was determined in the safety provisions based on the emission level used at the time of assessment for the licensing of the construction of the reactor.

In FY2003, the amount of released waste was lower than the target emission control levels at both the Fugen Power Station and Monju facilities.

The results of the evaluation, which was performed in accordance with the "Guideline concerning the target dose level of the local residents of light water nuclear power reactor facilities" show that the equivalent dose of public exposure was less than 1 μSv per year.

3) Nuclear Fuel Fabrication facilities

The release of gaseous and liquid waste of nuclear fuel fabrication facilities is controlled so that the three-month average concentrations do not exceed the target concentration control limit levels, which were determined in the safety provisions not to exceed the limit levels prescribed by the provisions.

In every quarter of FY 2003, the amount of released waste satisfied the target concentration control levels.

4) Reprocessing Facilities

The release of gaseous and liquid radioactive waste is controlled not to exceed the annual emission control levels, which were determined in the safety provisions based on the emission level used at the time of assessment for licensing of the facilities (approval of construction).

In FY2003, the amount of released waste satisfied the target control limit levels at both the Tokai Works (reprocessing facility) of the Japan Nuclear Cycle Development Institute (JNC) and the Japan Nuclear Fuel Limited, Reprocessing Plant (reprocessing facility).

The results of the evaluation, which was performed based on the evaluation method used in the assessment for the licensing of the facilities (approval of construction) show that the equivalent dose of public exposure was less than 1 μSv per year.

5) Radioactive Waste Burial and Waste Management Facilities

The release of gaseous and liquid waste of radioactive waste disposal facilities and waste management facilities is controlled so that the three-month average concentrations do not exceed the target concentration control limit levels, which were determined in the safety provisions.

In every quarter of FY 2003, the amount of released waste satisfied the target concentration control levels.

For reference purposes, the amount of released gaseous and liquid radioactive waste from nuclear power reactor facilities in a commercial, and research and development stage on an annual basis since FY1994 is shown in reference documents 1 to 4.

The radioactivity of released gaseous and liquid radioactive waste was measured in accordance with the "Guideline for Measurement of Released Radioactive Materials from Light Water Nuclear Power Reactor Facilities". Concentrations of released radioactivity that are below the detection limit are indicated as N.D. in the tables.