

Reference Material 2. Release of Radioactive Iodine in Radioactive Gaseous Waste by Fiscal Year

(1) Commercial Nuclear Power Reactor Facilities

(Unit: Bq)

FY Power Station	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Hokkaido Electric Power Co., Inc., Tomari Power Station	N.D.	N.D.	N.D.	1.2E+05	N.D.	8.7E+04	N.D.	6.9E+05 <sup>*1</sup>	N.D.	N.D.
Tohoku Electric Power Co., Inc., Onagawa NPS	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	2.7E+10 <sup>*1</sup>	1.0E+09 <sup>*1</sup>	N.D.	N.D.
Tohoku Electric Power Co., Inc., Higashidori NPS	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	8.8E+05 <sup>*1</sup>	N.D.	N.D.
Tokyo Electric Power Co., Inc., Fukushima Daiichi NPS	N.D.	N.D.	N.D.	N.D.	N.D.	5.3E+05	- <sup>*2</sup>	- <sup>*2</sup>	- <sup>*2, *3</sup>	N.D. <sup>*3</sup>
Tokyo Electric Power Co., Inc., Fukushima Daini NPS	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	6.2E+11 <sup>*1</sup>	1.9E+10 <sup>*1</sup>	N.D.	N.D.
Tokyo Electric Power Co., Inc., Kashiwazaki-Kariwa NPS	N.D.	N.D.	N.D.	2.3E+07	N.D.	N.D.	1.6E+07 <sup>*1</sup>	8.4E+06 <sup>*5</sup>	N.D.	N.D.
Chubu Electric Power Co., Inc., Hamaoka NPS	N.D.	2.0E+03	N.D.	N.D.	N.D.	3.0E+05	7.9E+08 <sup>*1</sup>	4.0E+07 <sup>*1</sup>	N.D.	N.D.
Hokuriku Electric Power Co., Inc., Shika NPS	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Kansai Electric Power Co., Inc., Mihama Power Station	N.D.	N.D.	N.D.	N.D.	1.2E+05	8.4E+04	1.2E+05	1.2E+06 <sup>*1</sup>	N.D.	N.D.
Kansai Electric Power Co., Inc., Takahama Power Station	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	1.4E+04 <sup>*1</sup>	1.4E+06 <sup>*1</sup>	N.D.	N.D.
Kansai Electric Power Co., Inc., Ohi Power Station	1.9E+08	N.D.	N.D.	N.D.	1.7E+06	N.D.	2.7E+05 <sup>*1</sup>	2.2E+06 <sup>*1</sup>	N.D.	N.D.
Chugoku Electric Power Co., Inc., Shimane NPS	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	2.5E+06 <sup>*1</sup>	N.D.	N.D.
Shikoku Electric Power Co., Inc., Ikata Power Station	N.D.	N.D.	7.3E+05	1.1E+05	N.D.	9.9E+04	1.7E+04 <sup>*1</sup>	9.5E+05 <sup>*1</sup>	N.D.	N.D.
Kyushu Electric Power Co., Inc., Genkai NPS	N.D.	4.6E+06	3.9E+06	N.D.	N.D.	N.D.	3.2E+06 <sup>*1</sup>	8.4E+05 <sup>*1</sup>	N.D.	N.D.
Kyushu Electric Power Co., Inc., Sendai NPS	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	1.6E+05 <sup>*1</sup>	N.D.	N.D.
Japan Atomic Power Co., Ltd., Tokai Power Station	/	/	/	/	/	/	/	/	/	/
Japan Atomic Power Co., Ltd., Tokai No. 2 Power Station	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	6.1E+09 <sup>*1</sup>	4.9E+08 <sup>*1</sup>	N.D.	N.D.
Japan Atomic Power Co., Ltd., Tsuruga Power Station	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	6.8E+05 <sup>*1</sup>	N.D.	N.D.
Total (excluding N.D.)	1.9E+08	4.6E+06	4.6E+06	2.3E+07	1.8E+06	1.1E+06	6.5E+11 <sup>*4</sup>	2.1E+10 <sup>*4</sup>	- <sup>*4</sup>	- <sup>*4</sup>

Note: Radioactivity measured at Tokai Power Station, Japan Atomic Power Co., Ltd. in FY2010 (2.4E+08) and FY2011 (1.4E+07) is presumed to be attributable to the accident at Fukushima Daiichi NPS.

\*5: Includes the release presumed to be associated with the accident at Fukushima Daiichi NPS (FY 2011: 7.7E+0.6).