

Reference Material 2. Release of Iodine in Radioactive Gaseous Waste by Fiscal Year

(1) Commercial Nuclear Power Reactor Facilities

(Unit: Bq)

Power Station	FY	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014
Hokkaido Electric Power Co., Inc., Tomari Nuclear Power Station		N.D.	N.D.	1.2E+05	N.D.	8.7E+04	N.D.	6.9E+05 <sup>*1</sup>	N.D.	N.D.	N.D.
Tohoku Electric Power Co., Inc., Onagawa Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	2.7E+10 <sup>*1</sup>	1.0E+09 <sup>*1</sup>	N.D.	N.D.	N.D.
Tohoku Electric Power Co., Inc., Higashidori Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	8.8E+05 <sup>*1</sup>	N.D.	N.D.	N.D.
Tokyo Electric Power Co., Inc., Fukushima Daiichi Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	5.3E+05	— <sup>*2</sup>	— <sup>*2</sup>	— <sup>*2,3</sup>	N.D. <sup>*3</sup>	N.D. <sup>*3</sup>
Tokyo Electric Power Co., Inc., Fukushima Daiini Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	6.2E+11 <sup>*1</sup>	1.9E+10 <sup>*1</sup>	N.D.	N.D.	N.D.
Tokyo Electric Power Co., Inc., Kashiwazaki-Kariwa Nuclear Power Station		N.D.	N.D.	2.3E+07	N.D.	N.D.	1.6E+07 <sup>*1</sup>	8.4E+06 <sup>*6</sup>	N.D.	N.D.	N.D.
Chubu Electric Power Co., Inc., Hamaoka Nuclear Power Station		2.0E+03	N.D.	N.D.	N.D.	3.0E+05	7.9E+08 <sup>*1</sup>	4.0E+07 <sup>*1</sup>	N.D.	N.D.	N.D.
Hokuriku Electric Power Co., Inc., Shika Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
Kansai Electric Power Co., Inc., Mihama Nuclear Power Station		N.D.	N.D.	N.D.	1.2E+05	8.4E+04	1.2E+05	1.2E+06 <sup>*1</sup>	N.D.	N.D.	N.D.
Kansai Electric Power Co., Inc., Takahama Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	1.4E+04 <sup>*1</sup>	1.4E+06 <sup>*1</sup>	N.D.	N.D.	N.D.
Kansai Electric Power Co., Inc., Ohi Nuclear Power Station		N.D.	N.D.	N.D.	1.7E+06	N.D.	2.7E+05 <sup>*1</sup>	2.2E+06 <sup>*1</sup>	N.D.	N.D.	N.D.
Chugoku Electric Power Co., Inc., Shimane Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	2.5E+06 <sup>*1</sup>	N.D.	N.D.	N.D.
Shikoku Electric Power Co., Inc., Ikata Nuclear Power Station		N.D.	7.3E+05	1.1E+05	N.D.	9.9E+04	1.7E+04 <sup>*1</sup>	9.5E+05 <sup>*1</sup>	N.D.	N.D.	N.D.
Kyushu Electric Power Co., Inc., Genkai Nuclear Power Station		4.6E+06	3.9E+06	N.D.	N.D.	N.D.	3.2E+06 <sup>*1</sup>	8.4E+05 <sup>*1</sup>	N.D.	N.D.	N.D.
Kyushu Electric Power Co., Inc., Sendai Nuclear Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	1.6E+05 <sup>*1</sup>	N.D.	N.D.	N.D.
Japan Atomic Power Company, Tokai Power Station											
Japan Atomic Power Company, Tokai No. 2 Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	6.1E+09 <sup>*1</sup>	4.9E+08 <sup>*1</sup>	N.D.	N.D.	N.D.
Japan Atomic Power Company, Tsuruga Power Station		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	6.8E+05 <sup>*1</sup>	N.D.	N.D.	N.D.
Total (excluding N.D.)		4.6E+06	4.6E+06	2.3E+07	1.8E+06	1.1E+06	6.5E+11 <sup>*4</sup>	2.1E+10 <sup>*4</sup>	— <sup>*4</sup>	— <sup>*4</sup>	— <sup>*4</sup>

Note: Radioactivity measured at Tokai Power Station, Japan Atomic Power Co., Ltd. in FY2010 (2.4E+08) and FY2011 (1.4E+07) is presumed to be attributable to the accident at Fukushima Daiichi Nuclear Power Station .

\*6: Includes the release presumed to be associated with the accident at Fukushima Daiichi Nuclear Power Station (FY 2011: 7.7E+0.6).