

(1) Commercial Nuclear Power Reactor Facilities

Power station		Radioactive gaseous waste		Radioactive liquid waste [excluding ^3H] (Bq)
		Noble gases (Bq)	Iodine [^{131}I] (Bq)	
Hokkaido Electric Power Co., Inc., Tomari Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	1.3E+15	1.2E+10	1.1E+11
Tohoku Electric Power Co., Inc., Onagawa Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	3.8E+15	1.3E+11	1.1E+10
Tohoku Electric Power Co., Inc., Higashidori Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	1.2E+15	2.0E+10	3.7E+09
Tokyo Electric Power Co., Inc., Fukushima Daiichi Nuclear Power Station	Nuclear reactor facilities total	*1 N.D.	*1 N.D.	No release record
	Annual release control target	*1 2.8E+15	*1 1.4E+11	*1 7.4E+10
Tokyo Electric Power Co., Inc., Fukushima Daiini Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	5.5E+15	2.3E+11	1.4E+11
Tokyo Electric Power Co., Inc., Kashiwazaki-Kariwa Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	6.7E+15	2.3E+11	2.5E+11
Chubu Electric Power Co., Inc., Hamaoka Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	*2 3.6E+15	*2 1.1E+11	*3 3.7E+10
Hokuriku Electric Power Co., Inc., Shika Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	2.3E+15	4.8E+10	7.4E+10
Kansai Electric Power Co., Inc., Mihama Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	2.1E+15	7.3E+10	1.1E+11
Kansai Electric Power Co., Inc., Takahama Nuclear Power Station	Nuclear reactor facilities total	2.5E+08	N.D.	N.D.
	Annual release control target	3.3E+15	6.2E+10	1.4E+11

Note: The release records at Fukushima Daiichi NPS are those of radioactive liquid waste released from drainage equipment in a managed manner. Release related to the Great East Japan Earthquake is not included.

*1: The indicated values for radioactive gaseous wastes are the recorded values and annual release control target values at the common ventilation stack for Units 5 and 6, which are managed in accordance with the Fukushima Daiichi implementation plan, and the incinerator building ventilation stack. The indicated value for radioactive liquid wastes (excluding ^3H) is the release control target at drainage ports for Units 5 and 6.

At present, no release control target has been specified in the Fukushima Daiichi implementation plan for the drainage ports of Units 1 to 4.

For ventilation ports and ventilation monitoring equipment for which actual measurement was impossible due to the effects of the Great East Japan Earthquake, the amount additionally released from each unit was measured, and the total amount released from Units 1 to 4 was evaluated to be less than $5.00\text{E} + 9$ Bq per year.

*2: This release control target is the total value for Units 3 to 5. The value for Units 1 and 2 is the total value up to the transition to Phase 2 of decommissioning (February 3, 2016), and was less than the measurement concentration lower limits for both noble gases and iodine.

*3: This release control target is applied to each of Units 3 to 5. The value applied to each of Units 1 and 2 is $3.0\text{E}+08$.

Power station		Radioactive gaseous waste		Radioactive liquid waste [excluding ^3H] (Bq)
		Noble gases (Bq)	Iodine [^{131}I] (Bq)	
Kansai Electric Power Co., Inc., Ohi Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	4.0E+15	1.0E+11	1.4E+11
Chugoku Electric Power Co., Inc., Shimane Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	8.4E+14	4.3E+10	7.4E+10
Shikoku Electric Power Co., Inc., Ikata Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	1.5E+15	8.1E+10	1.1E+11
Kyushu Electric Power Co., Inc., Genkai Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	2.2E+15	5.8E+10	1.4E+11
Kyushu Electric Power Co., Inc., Sendai Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	1.7E+15	6.2E+10	7.4E+10
Japan Atomic Power Company, Tokai Power Station	Nuclear reactor facilities total			1.4E+05
	Annual release control target			*4 3.4E+07
Japan Atomic Power Company, Tokai No. 2 Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	1.4E+15	5.9E+10	3.7E+10
Japan Atomic Power Company, Tsuruga Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release control target	1.7E+15	3.8E+10	7.4E+10

Note: The radioactivity (Bq) of released gaseous (or liquid) waste was obtained by multiplying the concentration of radioactive material (Bq/cm³) in the released gases (or liquids) by the amount of released gases (or liquids). N.D. is used to indicate values lower than the detection limit concentration.

Detection limit concentrations (Bq/cm³) are as follows.

Radioactive noble gases: 2E-02 or less

Radioactive iodine: 7E-09 or less

Radioactive liquid waste (excluding ^3H): 2E-02 or less (represented by a value of ^{60}Co)

*4: Release control targets are for ^{60}Co , ^{137}Cs , ^{152}Eu , and ^{154}Eu .