

(2) Nuclear Power Reactor Facilities at the Research and Development Stage

Facility		Radioactive gaseous waste		
		Noble gases (Bq)	Iodine [¹³¹ I] (Bq)	Tritium [³ H] (Bq)
Japan Atomic Energy Agency, Fugen Decommissioning Engineering Center	Nuclear reactor facilities total	N.D.	N.D.	2.7E+10
	Annual release control target	*6 —	*6 —	*7 1.4E+13
Japan Atomic Energy Agency, Sector of Fast Reactor Research and Development, Prototype Fast Breeder Reactor Monju	Nuclear reactor facilities total	N.D.	N.D.	2.4E+08
	Annual release control target	8.2E+13	1.5E+08	—

*5

Facility		Radioactive liquid waste	
		All nuclides [excluding ³ H] (Bq)	Tritium [³ H] (Bq)
Japan Atomic Energy Agency, Fugen Decommissioning Engineering Center	Nuclear reactor facilities total	N.D.	6.1E+11
	Annual release control target	*8 2.8E+08	*9 8.5E+12
Japan Atomic Energy Agency, Sector of Fast Reactor Research and Development, Prototype Fast Breeder Reactor Monju	Nuclear reactor facilities total	N.D.	*10 2.5E+07
	Annual release control target	5.5E+09	9.2E+12

Note: The radioactivity (Bq) of released gaseous (or liquid) waste was obtained by multiplying the concentration of radioactive material (Bq/cm³) in the released gases (or liquids) by the amount of released gases (or liquids).

"—" indicates that no annual release control target has been specified.

N.D. is used to indicate values lower than the detection limit concentration.

Detection limit concentrations (Bq/cm³) are as follows.

Radioactive noble gases: 2E-02 or less

Radioactive iodine: 7E-09 or less

Radioactive liquid waste (excluding ³H): 2E-02 or less (represented by a value of ⁶⁰Co)

*5: On October 1, 2014, the facility's name was changed from "Fugen Decommissioning Engineering Center Tsuruga Head Office, Japan Atomic Energy Agency" to "Fugen Decommissioning Engineering Center, Japan Atomic Energy Agency."

*6: Since October 1, 2003, due to a revision to the Operational Safety Program of Nuclear Facilities, the annual release control targets for noble gases and iodine have been removed from the annual release control targets for radioactive gaseous waste.

*7: Since February 12, 2008, due to a revision to the Operational Safety Program based on approval of the decommissioning plan, the annual release control target for tritium has been changed to 1.43E+13 (Bq/year).

*8: Since October 1, 2003, due to a revision to the Operational Safety Program of Nuclear Facilities, the annual release control target for radioactive liquid waste (excluding ³H) has been changed to 2.8E+08 (Bq/year).

*9: Since February 12, 2008, due to a revision to the Operational Safety Program based on approval of the decommissioning plan, the annual release control target for tritium has been changed to 8.5E+12 (Bq/year).

*10: The value includes tritium (N.D.) in the water and steam systems.