

3. Discharge Results of Radioactive Substance (^3H is excluded) in Radioactive Liquid Waste by Fiscal Year.

FY Power station	1981	1982	1983	1984	1985
Japan Atomic Power Company Co., Ltd. Tokai Power Station	1.6×10^8 (4.4×10^{-3})	1.9×10^8 (5.0×10^{-3})	1.4×10^8 (3.8×10^{-3})	1.2×10^8 (3.2×10^{-3})	1.0×10^8 (2.8×10^{-3})
Japan Atomic Power Company Co., Ltd. Tokai Daini Power Station	2.5×10^8 (6.8×10^{-3})	3.6×10^8 (9.8×10^{-3})	2.5×10^8 (6.8×10^{-3})	1.3×10^8 (3.6×10^{-3})	1.3×10^8 (3.4×10^{-3})
Japan Atomic Power Company Co., Ltd. Tsuruga Power Station	1.4×10^8 (3.7×10^{-3})	1.8×10^7 (8.4×10^{-4})	2.9×10^7 (7.8×10^{-4})	2.5×10^7 (6.8×10^{-4})	1.9×10^7 (5.2×10^{-4})
Tohoku Electric Power Co., Inc. Onagawa Nuclear Power Station			N.D.	N.D.	N.D.
Tokyo Electric Power Co., Inc. Fukushima Daiichi Nuclear Power Station	1.3×10^9 (3.6×10^{-2})	4.1×10^8 (1.1×10^{-2})	2.4×10^8 (6.4×10^{-3})	9.3×10^7 (2.5×10^{-3})	3.7×10^7 (1.0×10^{-3})
Tokyo Electric Power Co., Inc. Fukushima Daini Nuclear Power Station	N.D.	N.D.	N.D.	N.D.	N.D.
Tokyo Electric Power Co., Inc. Kashiwazaki-Kariwa Nuclear Power Station				N.D.	N.D.
Chubu Electric Power Co., Inc. Hamaoka Nuclear Power Station	5.2×10^8 (1.4×10^{-2})	3.3×10^8 (8.9×10^{-3})	1.0×10^8 (2.8×10^{-3})	7.0×10^7 (1.9×10^{-3})	5.6×10^7 (1.5×10^{-3})
Chugoku Electric Power Co., Inc. Shimane Nuclear Power Station	2.2×10^7 (5.9×10^{-4})	2.3×10^7 (6.2×10^{-4})	1.9×10^7 (5.0×10^{-4})	8.1×10^6 (2.2×10^{-4})	7.0×10^6 (1.9×10^{-4})
Hokkaido Electric Power Co., Inc. Tomari Power Station					
Kansai Electric Power Co., Inc. Mihama Power Station	8.9×10^7 (2.4×10^{-3})	8.5×10^7 (2.3×10^{-3})	1.0×10^8 (2.7×10^{-3})	3.7×10^7 (1.0×10^{-3})	2.2×10^7 (6.0×10^{-4})
Kansai Electric Power Co., Inc. Takahama Power Station	1.1×10^7 (3.1×10^{-4})	7.0×10^6 (1.9×10^{-4})	8.9×10^6 (2.4×10^{-4})	6.3×10^6 (1.7×10^{-4})	8.1×10^6 (2.2×10^{-4})
Kansai Electric Power Co., Inc. Ohi Power Station	1.9×10^8 (5.0×10^{-3})	2.9×10^7 (7.9×10^{-4})	2.2×10^7 (6.0×10^{-4})	1.9×10^7 (5.0×10^{-4})	2.1×10^7 (5.6×10^{-4})
Shikoku Electric Power Co., Inc. Ikata Power Station	2.6×10^6 (7.1×10^{-5})	N.D.	N.D.	N.D.	N.D.
Kyushu Electric Power Co., Inc. Genkai Nuclear Power Station	N.D.	N.D.	N.D.	N.D.	N.D.
Kyushu Electric Power Co., Inc. Sendai Nuclear Power Station			N.D.	N.D.	N.D.

* The influence of the Soviet Union Chernobyl nuclear plant accident is seen.

Note: The numerical value before FY1988 is conversion of the value reported in each curie into the unit of becquerel.

(Unit: becquerel, but, the curie in ())

1986	1987	1988	1989	1990
5.9×10^7 (1.6×10^{-3})	6.7×10^7 (1.8×10^{-3})	3.1×10^7 (8.5×10^{-4})	1.5×10^7	3.4×10^7
1.2×10^8 (3.3×10^{-3})	N.D.	N.D.	N.D.	N.D.
1.2×10^7 (3.3×10^{-4})	1.1×10^7 (3.0×10^{-4})	1.1×10^7 (3.0×10^{-4})	4.2×10^6	5.6×10^6
N.D.	N.D.	N.D.	N.D.	N.D.
1.0×10^7 (2.7×10^{-4})	6.7×10^6 (1.8×10^{-4})	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	7.3×10^5	N.D.
3.0×10^7 (8.0×10^{-4})	1.4×10^7 (3.9×10^{-4})	1.2×10^7 (3.3×10^{-4})	1.1×10^7	9.1×10^6
8.9×10^6 (2.4×10^{-4})	8.1×10^6 (2.2×10^{-4})	5.9×10^6 (1.6×10^{-4})	3.4×10^6	6.2×10^5
*		N.D.	N.D.	N.D.
1.5×10^7 (4.0×10^{-4})	1.7×10^7 (4.7×10^{-4})	2.1×10^7 (5.6×10^{-4})	6.5×10^6	1.6×10^7
1.3×10^7 (3.6×10^{-4})	2.7×10^6 (7.2×10^{-5})	N.D.	N.D.	N.D.
1.6×10^7 (4.4×10^{-4})	4.4×10^6 (1.2×10^{-4})	2.1×10^5 (5.7×10^{-8})	N.D.	7.4×10^5
N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.