

3. Discharge Results of Radioactive Substance ( $^3\text{H}$  is excluded) in Radioactive Liquid Waste by Fiscal Year.

Power station	FY	1983	1984	1985	1986
Japan Atomic Power Company Co., Ltd. Tokai Power Station		$1.4 \times 10^8$ ( $3.8 \times 10^{-3}$ )	$1.2 \times 10^8$ ( $3.2 \times 10^{-3}$ )	$1.0 \times 10^8$ ( $2.8 \times 10^{-3}$ )	$5.9 \times 10^7$ ( $1.6 \times 10^{-3}$ )
Japan Atomic Power Company Co., Ltd. Tokai Daini Power Station		$2.5 \times 10^8$ ( $6.8 \times 10^{-3}$ )	$1.3 \times 10^8$ ( $3.4 \times 10^{-3}$ )	$1.3 \times 10^8$ ( $3.4 \times 10^{-3}$ )	$1.2 \times 10^8$ ( $3.3 \times 10^{-3}$ )
Japan Atomic Power Company Co., Ltd. Tsuruga Power Station		$2.9 \times 10^7$ ( $7.8 \times 10^{-4}$ )	$2.5 \times 10^7$ ( $6.8 \times 10^{-4}$ )	$1.9 \times 10^7$ ( $5.2 \times 10^{-4}$ )	$1.2 \times 10^7$ ( $3.3 \times 10^{-4}$ )
Tohoku Electric Power Co., Inc. Onagawa Nuclear Power Station		N.D.	N.D.	N.D.	N.D.
Tokyo Electric Power Co., Inc. Fukushima Daiichi Nuclear Power Station		$2.4 \times 10^8$ ( $6.4 \times 10^{-3}$ )	$9.3 \times 10^7$ ( $2.5 \times 10^{-3}$ )	$3.7 \times 10^7$ ( $1.0 \times 10^{-3}$ )	$1.0 \times 10^7$ ( $2.7 \times 10^{-4}$ )
Tokyo Electric Power Co., Inc. Fukushima Daini Nuclear Power Station		N.D.	N.D.	N.D.	N.D.
Tokyo Electric Power Co., Inc. Kashiwazaki-Kariwa Nuclear Power Station			N.D.	N.D.	N.D.
Chubu Electric Power Co., Inc. Hamaoka Nuclear Power Station		$1.0 \times 10^8$ ( $2.8 \times 10^{-3}$ )	$7.0 \times 10^7$ ( $1.9 \times 10^{-3}$ )	$5.6 \times 10^7$ ( $1.5 \times 10^{-3}$ )	$3.0 \times 10^7$ ( $8.0 \times 10^{-4}$ )
Hokuriku Electric Power Co. Shika Nuclear Power Station					
Chugoku Electric Power Co., Inc. Shimane Nuclear Power Station		$1.9 \times 10^7$ ( $5.0 \times 10^{-4}$ )	$8.1 \times 10^6$ ( $2.2 \times 10^{-4}$ )	$7.0 \times 10^6$ ( $1.9 \times 10^{-4}$ )	$8.9 \times 10^6$ ( $9.4 \times 10^{-4}$ )
Hokkaido Electric Power Co., Inc. Tomari Power Station					
Kansai Electric Power Co., Inc. Mihama Power Station		$1.0 \times 10^8$ ( $2.7 \times 10^{-3}$ )	$3.7 \times 10^7$ ( $1.0 \times 10^{-3}$ )	$2.2 \times 10^7$ ( $6.0 \times 10^{-4}$ )	$*1.5 \times 10^7$ ( $4.0 \times 10^{-4}$ )
Kansai Electric Power Co., Inc. Takahama Power Station		$8.9 \times 10^6$ ( $2.4 \times 10^{-4}$ )	$6.3 \times 10^6$ ( $1.7 \times 10^{-4}$ )	$8.1 \times 10^6$ ( $2.2 \times 10^{-4}$ )	$1.3 \times 10^7$ ( $3.6 \times 10^{-4}$ )
Kansai Electric Power Co., Inc. Ohi Power Station		$2.2 \times 10^7$ ( $6.0 \times 10^{-4}$ )	$1.9 \times 10^7$ ( $5.0 \times 10^{-4}$ )	$2.1 \times 10^7$ ( $5.6 \times 10^{-4}$ )	$1.6 \times 10^7$ ( $4.4 \times 10^{-4}$ )
Shikoku Electric Power Co., Inc. Ikata Power Station		N.D.	N.D.	N.D.	N.D.
Kyushu Electric Power Co., Inc. Genkai Nuclear Power Station		N.D.	N.D.	N.D.	N.D.
Kyushu Electric Power Co., Inc. Sendai Nuclear Power Station		N.D.	N.D.	N.D.	N.D.

Note: The numerical value before FY 1988 is conversion of the value reported in each curie into the unit of becquerel.

(Unit: becquerel, but, the curie in ( ) )

1987	1988	1989	1990	1991	1992
$6.7 \times 10^3$ ( $1.8 \times 10^{-3}$ )	$3.1 \times 10^7$ ( $8.5 \times 10^{-4}$ )	$1.5 \times 10^7$	$3.4 \times 10^7$	$1.6 \times 10^7$	$1.6 \times 10^7$
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$1.1 \times 10^7$ ( $3.0 \times 10^{-4}$ )	$1.1 \times 10^7$ ( $3.0 \times 10^{-4}$ )	$4.2 \times 10^6$	$5.6 \times 10^6$	$6.6 \times 10^6$	$2.5 \times 10^6$
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
$6.7 \times 10^6$ ( $1.8 \times 10^{-4}$ )	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	$7.3 \times 10^5$	N.D.	N.D.	N.D.
$1.4 \times 10^7$ ( $3.9 \times 10^{-4}$ )	$1.2 \times 10^7$ ( $3.3 \times 10^{-4}$ )	$1.1 \times 10^7$	$9.1 \times 10^6$	$5.2 \times 10^6$	$2.4 \times 10^6$
				N.D.	N.D.
$8.1 \times 10^6$ ( $2.2 \times 10^{-4}$ )	$5.9 \times 10^6$ ( $1.6 \times 10^{-4}$ )	$3.4 \times 10^6$	$6.2 \times 10^5$	$1.5 \times 10^6$	$2.4 \times 10^6$
	N.D.	N.D.	N.D.	N.D.	N.D.
$1.7 \times 10^7$ ( $4.7 \times 10^{-4}$ )	$2.1 \times 10^7$ ( $5.6 \times 10^{-4}$ )	$6.5 \times 10^6$	$1.6 \times 10^7$	$5.1 \times 10^5$	$3.0 \times 10^6$
$2.7 \times 10^6$ ( $7.2 \times 10^{-5}$ )	N.D.	N.D.	N.D.	N.D.	N.D.
$4.4 \times 10^6$ ( $1.2 \times 10^{-4}$ )	$2.1 \times 10^5$ ( $5.7 \times 10^{-6}$ )	N.D.	$7.4 \times 10^5$	N.D.	$7.8 \times 10^4$
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
N.D.	N.D.	N.D.	N.D.	N.D.	N.D.