

Table V-2 Transition of Gross Radioactive Dose by Type of Reactors

(Unit : rem)

| Type of Reactor \ FY | 1974 | 1975 | 1976 | 1977 | 1978 | 1979 | 1980 | 1981 | 1982 | 1983 |
|----------------------|---------------|---------------|---------------|---------------|----------------|----------------|----------------|----------------|----------------|----------------|
| BWR | (6) 2,216 | (6) 3,982 | (6) 4,846 | (10) 6,632 | (11) 11,357 | (11) 9,629 | (11) 9,759 | (12) 9,760 | (12) 9,125 | (14) 8,422 |
| PWR | (5) 792 | (6) 904 | (7) 1,252 | (8) 1,366 | (9) 1,676 | (9) 1,870 | (10) 2,953 | (11) 2,934 | (11) 3,343 | (12) 3,363 |
| GCR | (1) 119 | (1) 112 | (1) 143 | (1) 119 | (1) 94 | (1) 86 | (1) 110 | (1) 73 | (1) 77 | (1) 82 |
| Total | (12) 3,127 | (13) 4,998 | (14) 6,241 | (19) 8,117 | (21) 13,127 | (21) 11,585 | (22) 12,747 | (24) 12,718 | (24) 12,500 | (27) 11,867 |

(Remark) The value in the parentheses is the number nuclear reactors.
658 rem is reduced from radioactive dose of BW R compared with the previous year,
However, this is because of the decrease in SCC measurement.