

Table - 1 Collective Dose and Periodical Inspection

(Unit : person*rem)

Type of Reactor	The Name of Power Station	Previous FY	F Y 1 9 8 5												Total
			The First Quarter			The First Quarter			The First Quarter			The First Quarter			
			April	May	June	July	August	September	October	November	December	January	February	March	
G C R	Toukai	140	29			39			27			45			140
B W R	Toukai Daini	810 12/12	47			50			48			632			777
	Tsuruga	1,127	317 12/12 (1,164)			43			55			97			511
	Onagawa	9	62 4/3 1st (70)			2			2			1			67
	Fukushima Daiichi (NO. 1)	4,750	1,355 3/25 11th (887)			1,045 8/7			1,115 11/8			1,145			4,660
	(NO. 2)														
	(NO. 3)														
	(NO. 4)														
	(NO. 5)														
	(NO. 6)														
	Fukushima Daini (No. 1)	461	28			21			102			91			241
	(No. 2)	1/20	4/17 1st 5/17 (89)						11/21			3rd (148) 2/20 3/4			
	(No. 3)		6/21 Operation Started									3/1 2nd			
	Kashiwazaki-Kariwa (No. 1)	3	7			6			4			3			20
						9/18 Operation Started									
Hamaoka (No. 1)	1,277	199			356			60			619			1,233	
(No. 2)		5/25			6th (529)			9/26 10/22			1/18 8th				
Shimane	364	8			10			18			369			404	
											1/9 11th				
P W R	Mihama (No. 1)	745	16			129			323			21			489
	(No. 2)	12/18	4/16 5/9 9th (324)						10/7 7th (237) 12/16			1/14			
	(No. 3)					8/24			7th (249) 11/29 12/20						
	Takahama (No. 1)	913	43			322			74			25			465
	(No. 2)	8/27	4/17 5/10 7th (715)			7/1			8th (398) 10/4 10/25						
	(No. 3)								11/6			1st (66) 1/23 2/21			
	(No. 4)		6/5 Operation Started												
	Ohmi (No. 1)	530	649			360			385			17			1,411
	(No. 2)		4/1 5th (1,165)			8/26 9/25			9/3			5th (543) 12/17 1/17			
	Ikata (No. 1)	257	79			125			153			3			359
	(No. 2)		6/5 7th (170)			8/19 9/11			10/5 3rd (138) 12/18			1/17			
	Genkai (No. 1)	239	192			63			131			8			395
	(No. 2)		4/19 8th (271)			8/7 9/6			10/27 4th (128) 12/21			1/21			
	Sendai (No. 1)	98 2/2	6			13			2			66			87
(No. 2)		4/17 5/14 1st (90)						11/28 Operation Started			3/1 2nd				

(Remark) 1. The total of the Quarter is the total of three months

2. The value in the parentheses is the gross radioactive dose during inspection period, which is measured by TDL or a digital gauge with alarm

3. means joint operation